



BV LCIE
CHINA
Number

N° 2466AS05COGY54991

ATTESTATION of conformity with European Directives

Product: **MCB**
Reference **WSB1-63**
Issued to **ZHEJIANG WESTHOMES ELECTRIC CO.,LTD**
Address **No.188 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P.R.China**
Manufacturer **ZHEJIANG WESTHOMES ELECTRIC CO.,LTD**
Type C and B
Ue=230/400V~ or 240/415V~ (1P); 400/415V~ (2P, 3P, 4P)
In=1; 2; 3; 4; 6; 10; 16; 20; 25; 32; 40; 50; 63A
Ics=Icn=6000A
Technical characteristics **Energy limit class: 1 (according to EN 60898-1)**
Grid distance: 50mm
Ui=415V
Uimp=4kV
Screw diameter of load terminal =4,9mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 60898-1:2019	B240008	05/15/2024

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), May 15th, 2024.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.