

## **ATTESTATION**of conformity with European Directives

BV LCIE CHINA Number N° 2466AS11COGY57539

Product MCCB

Reference WCM8-125

Trademark Westhomes

Issued to ZHEJIANG WESTHOMES ELECTRIC CO.,LTD

Address No.188 Wei 17th Road, Yueqing economic Development Zone, Yueqing, Wenzhou,

Zhejiang Province, P.R.China

Manufacturer ZHEJIANG WESTHOMES ELECTRIC CO.,LTD

No.188 Wei 17th Road, Yueqing economic Development Zone, Yueqing, Wenzhou,

Zhejiang Province, P.R.China

Selectivity category: A; Number of poles: 3P, 3P+N

Ue: 415V~, 50/60Hz

Ie: 16A,20A,25A,32A,40A,50A,63A,80A,100A,125A

Icu=25kA; Ics=18kA

Technical characteristics
Ui=800V; Uimp=8kV

IP20 for front cover Pollution degree: 3

Reference temperature: 40°C

The submitted sample of the above equipment has been tested according to following European Directive and following standards:

## LVD Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2: 2017+A1: 2020; EN 60947-1: 2007 + A1: 2011 + A2: 2014	B240056	29/10/2024

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

Shanghai (P.R. China), November 18th, 2024.

**Product Line Manager** 

Charlie Chen

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document is related to the tested specimen of the described electrical sample.

Version: 10.1 / Feb.28 2024 Page 1 of 1