

IEC

IECEE



TM

Ref. Certif. No.

CN72851

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breaker

Name and address of the applicant

Zhejiang Westhomes Electric Co., Ltd
No.188 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang Westhomes Electric Co., Ltd
No.188 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Zhejiang Westhomes Electric Co., Ltd
No.188 Wei 17th Road, Yueqing Economic Development Zone,
Yueqing City, Zhejiang Province, P.R.China

Ratings and principal characteristics

Uimp:8kV;Ui:1000V;Ue:AC400V;In:25A,32A,40A,50A,63A,80A,100A,125A,140A,160A (Adjustable within 0.7In-1.0In);
Type of over-current release: Thermo-magnetic;
Ics:25kA;Icu:25kA;Selectivity category:A; 3P,4P(3 protected poles with a switched neutral pole); Suitable for isolation.

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

WM-160RT;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-2:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

(2025)MJDQ-CB1386

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.08,2025

Signature:

谢肇煦

Xie ZhaoXu

